



April 18, 2014

Sent via email, original by mail

Southern Fulton High School
13083 Buck Valley Road
Warfordsburg, PA 17267

Attention: **Hervey P. Hann**

Reference: **Metal Panel Options**
Southern Fulton High School Renovations
Lobar Project 13-035

Dear Mr. Hann:

Per your request at the April 16th job conference, please see the below options concerning the metal panel system.

Option #1: Available credit if the panels are returned

Per the manufacturer's attached letter, the panels cannot be returned as the paint finish specified is a custom product and the freight back and forth would be prohibitive.

Option #2: Cost for new, single color panels and flashings

The cost for new insulated wall panels and associated trim with a standard, smooth color finish would be \$89,240.00 for the material only.

Option #3: Possibility of turning the panels over & providing new flashings

Per the manufacturer's attached letter, the panels cannot be turned over and installed as the clip system designed to hold the panels onto the substrate will not work in a reversed position. Also, the finish on the backside of the panel is not a warranted finish system.


Option #4: Cost for dryvit

If dryvit is required in lieu of the metal panel system, a budget number for this work would be approximately \$95,000.00.

Please note that the costs above do not include labor or disposal fees associated with removing the original panels as these panels are the District's property.

If you have any questions or require additional information, please feel free to contact our office.

Sincerely,

A handwritten signature in black ink, appearing to read "Brandon Lebo". The signature is written in a cursive, slightly slanted style.

Brandon Lebo
Project Manager
Lobar, Inc.

Enclosure: Brock Associates Letter dated 4/17/14

cc: Frank Augustine – CRA Architects
Charlie Shughart – Lobar, Inc.

180 Blimmar Drive – Suite #2
Pittsburgh, PA 15205
Phone - 412-919-0690
Fax - 412-919-0689



April 17, 2014

**Blair Roofing, Inc.
509 Chimney Rocks Road
Hollidaysburg, PA 16648**

Attn: Mike Barton

Re: Southern Fulton H.S.

The following are the options concerning shipping back panels for credit and reversing panels for installing backwards.

- **Option #1**
The panels on site are of no value to the manufacturer and the freight would be prohibitive.
- **Option #2**
The panels cannot be turned backwards for installation because the clips wouldn't work in this direction.

Sincerely,

A handwritten signature in cursive script that reads 'Jon D. Farrer'.

Jon D. Farrer

E.O.E. M/F